



May 31, 2019

Mr. Sam Barna
Assistant Superintendent of Business and Operations
Oxford Community Schools
10 N. Washington St.
Oxford, MI 48371

RE: 2019 Asbestos Inspections Asbestos Containing Materials (ACM) List

Dear Mr. Barna:

Pursuant to your request, Nova Environmental, Inc., is providing the 2019 Asbestos Inspections *Homogeneous Area Listing* pages (and any subsequent sampling) for the following schools: Axford Elementary School, Clear Lake Elementary School, Lakeville Elementary School, Leonard Elementary School, Oxford Elementary School and Oxford High School.

The *Homogeneous Area Listing* pages list suspected materials and identify the materials as “Negative”, “Positive” and “Assumed” for ACM. Bulk samples were collected for the Negative and Positive materials. Assumed materials are those that are not able to be sampled (without destructive measures) such as fire doors, wood floors and boilers. They are assumed positive.

Over the past 120 years, asbestos has been used in the construction of thousands of buildings, including schools and homes, throughout the United States. The EPA has listed over 3,500 products that have contained asbestos, many of these as building components.

It is important to understand that the simple presence of asbestos in a building is not a concern. It is when the asbestos fibers are released from the building component into the air that it becomes problematical. Therefore, it is during renovation and demolition activities that the bulk of the applicable asbestos regulatory standards apply.

As a result of passing the bond issue, the Oxford Community School’s administration recently contracted with an environmental consulting and testing firm, Nova Environmental, Inc. to conduct updated asbestos inspections within the buildings in order to ensure that the District knows where asbestos is located. The inspections serve two primary purposes.

1. To ensure that the presence, quantity and location of asbestos can be provided to outside contractors (as required by the OSHA Asbestos Construction Standard and the EPA’s AHERA regulation);
2. To identify those locations of asbestos that will need to be removed in order to support the bond issue construction activities (as required by applicable Federal and Michigan State regulations).

Page 2
Letter to Mr. Sam Barna

Nova Environmental, Inc. can provide additional information presentations on asbestos upon request.

Let me know if you have any questions.

Thank you,
NOVA ENVIRONMENTAL, INC.

A handwritten signature in blue ink, appearing to read 'Adam Amin', with a stylized, elongated horizontal stroke at the end.

Adam Amin
Environmental Consultant

Enc.

Axford Elementary School

Homogeneous Area List

Homogeneous Area Description	HA#	Asbestos
Concrete	1	Negative
Cinderblock	2	Negative
Cinderblock Mortar	3	Negative
12" x 12" Floor Tile - Gray w/ Multi-color Specks	4	Negative
Mastic for 12" x 12" Floor Tile - Gray w/ Multi-color Specks	5	Negative
4" Covebase - Gray	6	Negative
Mastic for 4" Covebase - Gray	7	Negative
Carpet Glue - Yellow	8	Negative
Window Caulk - Brown	9	Positive
Door Caulk - Gray	10	Positive
Sink Undercoating - Gray	11	Negative
Drywall	12	Negative
Drywall Mud	13	Negative
Drywall Tape	14	Negative
4' x 2' Ceiling Panel - Dots/Gouges	15	Negative
4' x 2' Ceiling Panel - Dots/Long Gouges	16	Negative
Troweled on Ceiling - Finishcoat	17	Positive
Troweled on Ceiling - Browncoat	18	Negative
9" x 9" Floor Tile - Tan	19	Positive
Mastic for 9" x 9" Floor Tile - Tan	20	Negative
White Board Gluepods	21	Assumed
Window Panel	22	Negative
Fire Stop - Brown	23	Negative
Rough Plaster Ceiling - Finishcoat	24	Negative
Rough Plaster Ceiling - Browncoat	25	Negative
Plaster Board Deck	26	Negative
12" x 12" Floor Tile - Cream w/ Beige Specks	27	Positive
Mastic for 12" x 12" Floor Tile - Cream w/ Beige Specks	28	Negative
1' x 1' Ceiling Tile - Dots/Gouges	29	Negative
Gluepods for 1' x 1' Ceiling Tile - Dots/Gouges	30	Negative
Tagged Door	31	Assumed
Tagged Door Frame	32	Assumed
Smooth Plaster Ceiling - Finishcoat	33	Negative
Smooth Plaster Ceiling - Browncoat	34	Negative
Fiberglass Pipe Insulation	35	Negative
Rough Plaster Wall - Finishcoat	36	Negative
Rough Plaster Wall - Browncoat	37	Negative
Unknown Black Mastic	38	Positive
Beam Caulk - White	39	Negative
Door Caulk - White	40	Negative
Wall Joint Caulk - White	41	Negative
Stair Tread - Brown Diamond	42	Negative
Mastic for Stair Tread - Brown Diamond	43	Negative
Sink Undercoating - White	44	Positive
Unknown Cream Floor Tile	45	Negative
Mastic for Unknown Cream Floor Tile	46	Positive
Door Caulk - Old White	47	Negative
2' x 4' Ceiling Panel - Tiny Dots	48	Negative
Old Fiberglass Pipe Insulation	49	Negative
Mud Fittings on Old Fiberglass Pipe Insulation	50	Negative
Chalk Board Gluepods	51	Assumed

Oxford Community SchoolsAxford Elementary School
Homogeneous Area List

Homogeneous Area Description	HA#	Asbestos
Brick	52	Negative
Brick Mortar	53	Negative
Vinyl Sheeting - Wood Pattern	54	Negative
Mastic for Vinyl Sheeting - Wood Pattern	55	Negative
4" Covebase - Brown	56	Negative
Mastic for 4" Covebase - Brown	57	Negative
Vibration Dampener - Black	58	Negative
Kiln Brick	59	Negative
Partition Wall	60	Negative
4' x 2' Ceiling Panel - Square Dots/Gouges	61	Negative
Wall Window Glaze - Black	62	Negative
Wall Window Caulk - White	63	Negative
Fiberglass Duct Insulation	64	Negative
Duct Sealant - Gray	65	Negative
Door Caulk - Brown	66	Negative
6" Covebase - Navy Blue	67	Negative
Mastic for 6" Covebase - Navy Blue	68	Negative
Vinyl Sheeting - Multi-color	69	Negative
Mastic for Vinyl Sheeting - Multi-color	70	Negative
2' x 4' Ceiling Panel - Smooth White	71	Negative
Concrete Vapor Barrier - Black	72	Negative
12" x 12" Floor Tile - Brown Mottled	73	Negative
Mastic for 12" x 12" Floor Tile - Brown Mottled	74	Negative
Exterior EIFS	75	Negative
Exterior Door Caulk - New Gray	76	Negative
Exterior Wall Joint Caulk - White	77	Negative
Exterior Brick	78	Negative
Exterior Brick Mortar	79	Negative
Exterior Window Caulk - Brown	80	Positive
Exterior Overhang	81	Negative
Exterior Door Caulk - Brown	82	Negative
Exterior Wall Joint Caulk - Old Gray	83	Negative
Boiler	84	Assumed



BULK SAMPLE RESULTS

CLIENT: Oxford Community Schools

BUILDING: Axford Elementary School

PROJECT #: CI0616/AE103

TYPE OF ANALYSIS: PLM

<u>SAMPLE I.D.</u>	<u>MATERIAL DESCRIPTION</u>	<u>CLASS</u>	<u>LOCATION OF SAMPLE</u>	<u>SAMPLE CONDITION</u>	<u>ASBESTOS DETECTED</u>	<u>%/TYPE</u>	<u>NON-ASBESTOS MATERIAL</u>
CI0616/AE103-001A	Rough Plaster Ceiling - Finishcoat	Surf.	Room 33	Non-Friable	None Detected	---	Refer to Analytical Report
CI0616/AE103-001B	Rough Plaster Ceiling - Browncoat	Surf.	Room 33	Non-Friable	None Detected	---	Refer to Analytical Report
CI0616/AE103-002A	Rough Plaster Ceiling - Finishcoat	Surf.	Room 34	Non-Friable	None Detected	---	Refer to Analytical Report
CI0616/AE103-002B	Rough Plaster Ceiling - Browncoat	Surf.	Room 34	Non-Friable	None Detected	---	Refer to Analytical Report



BULK SAMPLE RESULTS

CLIENT: Oxford Community Schools

BUILDING: Axford Elementary School

PROJECT #: CI0616/AE104

TYPE OF ANALYSIS: PLM

<u>SAMPLE I.D.</u>	<u>MATERIAL DESCRIPTION</u>	<u>CLASS</u>	<u>LOCATION OF SAMPLE</u>	<u>SAMPLE CONDITION</u>	<u>ASBESTOS DETECTED</u>	<u>%/TYPE</u>	<u>NON-ASBESTOS MATERIAL</u>
CI0616/AE104-001	AC Panel Caulk - Brown	Misc.	East Side of 2 nd Story portion of Building	Non-Friable	None Detected	---	Refer to Analytical Report
CI0616/AE104-002	AC Caulk - Brown	Misc.	East Side at 2 nd Story portion of Building	Non-Friable	None Detected	---	Refer to Analytical Report
CI0616/AE104-003	AC Panel Caulk - Brown	Misc.	East Side of 1 st Story portion of Building	Non-Friable	None Detected	---	Refer to Analytical Report
CI0616/AE104-004	AC Caulk - Brown	Misc.	East Side of 1 st Story portion of Building	Non-Friable	None Detected	---	Refer to Analytical Report

Clear Lake Elementary School

Homogeneous Area Listing

Homogeneous Area Description	HA#	Asbestos
Concrete	1	Negative
Cinderblock	2	Negative
Cinderblock Mortar	3	Negative
Brick	4	Negative
Brick Mortar	5	Negative
2' x 4' Ceiling Panel - Dots/Gouges	6	Negative
4" Covebase - Tan	7	Negative
Mastic for 4" Covebase - Tan	8	Negative
Duct Sealant - Gray	9	Negative
Old Fiberglass Pipe Insulation	10	Negative
Mud Fitting on Old Fiberglass Pipe Insulation	11	Positive
New Fiberglass Pipe Insulation	12	Negative
Aluminum Duct Insulation	13	Negative
Sink Undercoating - Black	14	Negative
Door Caulk - White	15	Negative
Carpet Glue - Yellow	16	Negative
Window Caulk - Brown	17	Negative
Window Glaze - Black	18	Negative
Wall Joint Caulk - White	19	Negative
4" Covebase - Gray	20	Negative
Mastic for 4" Covebase - Gray	21	Negative
Vinyl Sheeting - Multi-color	22	Negative
Mastic for Vinyl Sheeting - Multi-color	23	Negative
Wall Joint Caulk - Gray	24	Negative
Door Caulk - Brown	25	Negative
12" x 12" Floor Tile - White w/ Multi-color Specks	26	Negative
Mastic for 12" x 12" Floor Tile - White w/ Multi-color Specks	27	Negative
2' x 2' Ceiling Panel - Dots/Gouges	28	Negative
Sink Undercoating - Gray	29	Positive
Wall Window Caulk - Gray	30	Positive
Tagged Door	31	Assumed
Tagged Door Frame	32	Assumed
Wall Window Glaze - Black	33	Negative
Door Caulk - Gray	34	Positive
9" x 9" Floor Tile - Tan w/ Brown Streaks	35	Positive
Mastic for 9" x 9" Floor Tile - Tan w/ Brown Streaks	36	Negative
4" Covebase - Black	37	Negative
Mastic for 4" Covebase - Black	38	Negative
1' x 1' Ceiling Tiles - White w/ Deep Dots	39	Negative
Glue pods for 1' x 1' Ceiling Tiles - White w/ Deep Dots	40	Negative
Boiler - 2005	41	Assumed
Duct Sealant - Red	42	Negative
Drywall	43	Negative
Drywall Mud	44	Negative
Drywall Tape	45	Negative
2' x 4' Ceiling Panel - Dots/Deep Gouges	46	Negative
Beam Caulk - Gray	47	Positive
Beam Caulk - White	48	Negative
Corner Covebase - Black	49	Negative
Mastic for Corner Covebase - Black	50	Negative
Gym Wood Floor	51	Assumed

Oxford Community Schools

Clear Lake Elementary School

Homogeneous Area Listing

Homogeneous Area Description	HA#	Asbestos
Door Window Glaze - Black	52	Negative
Tectum Panel	53	Negative
Gluepods for Tectum Panel	54	Negative
12" x 12" Floor Tile - Gray Mottled	55	Negative
Mastic for 12" x 12" Floor Tile - Gray Mottled	56	Negative
2' x 4' Ceiling Panel - Smooth White	57	Negative
12" x 12" Floor Tile - Brown Mottled	58	Negative
Mastic for 12" x 12" Floor Tile - Brown Mottled	59	Positive
Sink Undercoating - White	60	Positive
2' x 2' Ceiling Panel - Textured White	61	Negative
Vinyl Sheeting - Blue	62	Negative
Mastic for Vinyl Sheeting - Blue	63	Negative
Exterior Brick	64	Negative
Exterior Brick Mortar	65	Negative
Exterior Window Caulk - Brown	66	Negative
Exterior Wall Joint Caulk - White	67	Positive
Exterior Door Caulk - Gray	68	Negative
Exterior Door Caulk - Old Gray	69	Negative
Exterior Vent Caulk - Gray	70	Negative

Lakeville Elementary School

Homogeneous Area Listing

Homogeneous Area Description	HA#	Asbestos
Concrete	1	Negative
Cinderblock	2	Negative
Cinderblock Mortar	3	Negative
2' x 4' Ceiling Panel - Dots/Gouges	4	Negative
4" Covebase - Tan	5	Negative
Mastic for 4" Covebase - Tan	6	Negative
Door Caulk - Gray	7	Negative
Door Caulk - White	8	Negative
Window Caulk - Gray	9	Negative
Carpet Glue - Yellow	10	Negative
Wall Joint Caulk - White	11	Negative
Old Fiber Glass Pipe Insulation	12	Negative
New Fiber Glass Pipe Insulation	13	Negative
Duct Sealant - Gray	14	Negative
Tectum Deck	15	Negative
2' x 2' Ceiling Panel - Dots/Gouges	16	Negative
Wall Window Glaze - Gray	17	Negative
Wall Window Caulk - Gray	18	Negative
12" x 12" Floor Tile - Beige w/ Multi-colored Specks	20	Positive
Mastic for 12" x 12" Floor Tile - Beige w/ Multi-colored Specks	21	Negative
Sink Undercoating - White	22	Negative
Tagged Door	24	Assumed
Tagged Door Frame	25	Assumed
Drywall	26	Negative
Drywall Mud	27	Negative
Drywall Tape	28	Negative
Brick	29	Negative
Brick Mortar	30	Negative
2" x 4" Ceiling Panel - Dots/Deep Gouges	31	Negative
Firestop - Red	32	Negative
Wall Joint Caulk - Gray	33	Negative
Mud Fittings on Old Fiberglass Pipe Insulation	34	Positive
Wall Window Glaze - Black	35	Negative
Boiler - 2005	36	Assumed
12" x 12" Floor Tile - Aqua Mottled	37	Negative
Mastic for 12" x 12" Floor Tile - Aqua Mottled	38	Negative
12" x 12" Floor Tile - Blue Mottled	39	Negative
Mastic for 12" x 12" Floor Tile - Blue Mottled	40	Negative
Door Caulk - Old Gray	41	Negative
9" x 9" Floor Tile - Cream Mottled	42	Positive
Mastic for 9" x 9" Floor Tile - Cream Mottled	43	Positive
4" Covebase - Black	44	Negative
Mastic for 4" Covebase - Black	45	Negative
4" Covebase - Gray	46	Negative
Mastic for 4" Covebase - Gray	47	Negative
Wall Window Glaze - Brown	48	Negative
2' x 2' Ceiling Panel - Dots/Deep Gouges	49	Negative
2' x 2' Ceiling Panel - Smooth White	50	Negative
Wall Window Caulk - White	51	Negative
Sink Undercoating - Black	52	Negative
Window Caulk - White	53	Negative

Lakeville Elementary School

Homogeneous Area Listing

Homogeneous Area Description	HA#	Asbestos
12" x 12" Floor Tile - Dark Blue Mottled	54	Negative
Mastic for 12" x 12" Floor Tile - Dark Blue Mottled	55	Negative
Vinyl Sheeting - Blue Mottled	56	Negative
Mastic for Vinyl Sheeting - Blue Mottled	57	Negative
Vinyl Sheeting - Purple Mottled	58	Negative
Mastic for Vinyl Sheeting - Purple Mottled	59	Negative
Vinyl Sheeting - Green Mottled	60	Negative
Mastic for Vinyl Sheeting - Green Mottled	61	Negative
Stair Tread - Brown	62	Negative
Mastic for Stair Tread - Brown	63	Negative
Stage Wood Floor	64	Assumed
2' x 2' Ceiling Panel - White Textured	65	Negative
Gym Wood Floor	66	Assumed
Beam Caulk - Gray	67	Negative
Door Window Glaze - Black	68	Negative
Exterior Vent Caulk - Brown	69	Negative
Exterior Brick	70	Negative
Exterior Brick Mortar	71	Negative
Exterior Door Caulk - Gray	72	Negative
Exterior Window Caulk - Gray	73	Negative
Exterior Wall Joint Caulk - Gray	74	Negative
Exterior Door Caulk - Old Gray	75	Negative

Oxford Community Schools

Leonard Elementary School

Homogeneous Area Listing

Homogeneous Area Description	HA#	Asbestos
Concrete	1	Negative
Cinderblock	2	Negative
Cinderblock Mortar	3	Negative
Brick	4	Negative
Brick Mortar	5	Negative
Drywall	6	Negative
Drywall Mud	7	Negative
Drywall Tape	8	Negative
2' x 4' Ceiling Panel - Dots/ Gouges	9	Negative
Sink Undercoating - Gray	10	Negative
12" x 12" Floor Tile - Beige w/ Multi-colored Specks	11	Negative
Mastic for 12" x 12" Floor Tile - Beige w/ Multi-colored Specks	12	Negative
Door Caulk - White	13	Negative
Door Window Glaze - Black	14	Negative
Tagged Door	15	Assumed
Tagged Frame	16	Assumed
Window Caulk - Brown	17	Negative
Wall Joint Caulk - White	18	Negative
4" Covebase - Tan	19	Negative
Mastic for 4" Covebase - Tan	20	Negative
Fiberglass Pipe Insulation	21	Negative
Duct Sealant - Tan	22	Negative
Aluminum Duct Insulation	23	Negative
Fire Stop - Red	24	Negative
Carpet Glue - Yellow	25	Negative
Partition Wall	26	Negative
Boiler - 2002	27	Assumed
Vent Caulk - Gray	28	Negative
4" Covebase - Gray	29	Negative
Mastic for 4" Covebase - Gray	30	Negative
Vinyl Sheeting - Multicolored	31	Negative
Mastic for Vinyl Sheeting - Multicolored	32	Negative
Door Caulk - Brown	33	Negative
2' x 2' Ceiling Panel - Dots/ Gouges	34	Negative
2" x 4" Ceiling Panel - White w/ Dots	35	Negative
Vibration Dampener - White	36	Assumed
Gym Wood Floor	37	Assumed
4" Covebase - Black	38	Negative
Mastic for 4" Covebase - Black	39	Negative
1' x 1' Ceiling Tile - White w/ Dots	40	Negative
Glue Pods for 1' x 1' Ceiling Tile - White w/ Dots	41	Negative
Old Fiberglass Pipe Insulation	42	Negative
Mud Fitting On Old Fiberglass Pipe Insulation	43	Negative
Plaster Ceiling - Finishcoat	44	Negative
Plaster Ceiling - Browncoat	45	Negative
Stair Tread - Gray	46	Negative
Mastic for Stair Tread - Gray	47	Negative
Door Caulk - Tan	48	Positive
6" Covebase - Black	49	Negative
Mastic for 6" Covebase - Black	50	Negative
Plaster Wall - Finishcoat	51	Negative

Leonard Elementary School

Homogeneous Area Listing

Homogeneous Area Description	HA#	Asbestos
Plaster Wall - Finishcoat	52	Negative
Vibration Dampener - Black	53	Negative
12" x 12" Floor Tile - Beige Modeled	54	Negative
Mastic for 12" x 12" Floor Tile - Beige Modeled	55	Positive
Sink Undercoating - Pink	56	Positive
Aircell Pipe Insulation	57	Positive
Exterior Door Caulk - Gray	58	Negative
Exterior Window Caulk - Brown	59	Negative
Exterior Window Glaze - Black	60	Negative
Exterior Wall Joint Caulk - White	61	Negative
Exterior Window Caulk - Black	62	Negative
Exterior Brick	63	Negative
Exterior Brick Mortar	64	Negative
Exterior Vent Caulk - Gray	65	Negative
Exterior Wall Joint Caulk - Tan	66	Negative
Exterior Vent Caulk - Black	67	Negative
Exterior Door Caulk - Black	68	Negative
Exterior Overhang	69	Negative
Exterior Overhang Caulk - Cream	70	Negative

Oxford Elementary School
Homogeneous Area Listing

Homogeneous Area Description	HA#	Asbestos
Concrete	1	Negative
Cinderblock	2	Negative
Cinderblock Mortar	3	Negative
Drywall	4	Negative
Drywall Mud	5	Negative
Drywall Tape	6	Negative
4" Covebase - Gray	7	Negative
Mastic for 4" Covebase - Gray	8	Negative
2' x 4' Ceiling Panel - Dots/ Deep Gouges	9	Negative
Fiberglass Pipe Insulation	10	Negative
Aluminum Duct Insulation	11	Negative
Tagged Door	12	Assumed
Tagged Door Frame	13	Assumed
Door Window Glaze - Black	14	Negative
Door Caulk - White	15	Negative
Window Caulk - Brown	16	Positive
Window Glaze - Brown	17	Negative
Wall Joint Caulk - White	18	Negative
Carpet Glue - Yellow	19	Negative
2' x 2' Ceiling Tile - White with Holes	20	Negative
2" x 4" Ceiling Panel - Dots	21	Negative
12" x 12" Floor Tile - Beige Modeled	22	Negative
Mastic for 12" x 12" Floor Tile - Beige Modeled	23	Negative
Sink Undercoating - Gray	24	Negative
Wall Window Caulk - White	25	Negative
Wall Window Glaze - Black	26	Negative
White Board Glue Pods	27	Negative
Brick	28	Negative
Brick Mortar	29	Negative
Door Caulk - Brown	30	Negative
Glue Pods for 2' x 2' Ceiling Tile - White with Holes	31	Negative
Gypsum Roof Deck	32	Negative
Fire Stop - Red	33	Negative
Duct Sealant - Gray	34	Negative
2" x 4" Ceiling Panel - White Textured	35	Negative
Vinyl Sheeting - Gray Marbled	36	Negative
Mastic for Vinyl Sheeting - Gray Marbled	37	Negative
Boiler - 1994	38	Assumed
Boiler - 2011	39	Assumed
Duct Caulk - Gray	40	Negative
Door Caulk - Black	41	Negative
Transite Ceiling Panel	42	Positive
2" x 4" Ceiling Panel - Deep Dots	43	Negative
Sink Undercoating - Black	44	Positive
Wall Window Glaze - Clear	45	Negative
12" x 12" Floor Tile - White w/ Gray Specks	46	Negative
Mastic for 12" x 12" Floor Tile - White w/ Gray Specks	47	Negative
4" Covebase - Green	48	Negative
Mastic for 4" Covebase - Green	49	Negative
Gym Wood Floor	50	Assumed
12" x 12" Floor Tile - White w/ Multi-colored streaks	51	Negative

Oxford Elementary School
Homogeneous Area Listing

Homogeneous Area Description	HA#	Asbestos
Mastic for 12" x 12" Floor Tile - White w/ Multi-colored streaks	52	Negative
Old Fiberglass Pipe Insulation	53	Negative
9" x 9" Floor Tile - Tan w/ Brown Streaks	54	Positive
Mastic for 9" x 9" Floor Tile - Tan w/ Brown Streaks	55	Negative
4" Covebase - Brown	56	Negative
Mastic for 4" Covebase - Brown	57	Negative
1' x 1' Ceiling Tile - White w/ Holes	58	Negative
Glue pods for 1' x 1' Ceiling Tile - White w/ Holes	59	Negative
Vinyl Sheeting - Multi-colored	60	Negative
Mastic for Vinyl Sheeting - Multi-colored	61	Negative
Window Caulk - Blue	62	Negative
2' x 4' Ceiling Panel - Smooth White	63	Negative
Door Caulk - New Brown	64	Negative
Wall Window Caulk - New Brown	65	Negative
4" x 4" Covebase - Tan	66	Negative
Mastic for 4" x 4" Covebase - Tan	67	Negative
1' x 1' Ceiling Tile - Deep Gouges	68	Negative
Glue Pods for 1' x 1' Ceiling Tile - Deep Gouges	69	Negative
Wall Joint Caulk - Brown	70	Positive
Wall Joint Caulk - Gray	71	Negative
12" x 12" Floor Tile - Orange Modeled	72	Negative
Mastic for 12" x 12" Floor Tile - Orange Modeled	73	Negative
12" x 12" Floor Tile - Green Modeled	74	Negative
Mastic for 12" x 12" Floor Tile - Green Modeled	75	Negative
2' x 2' Ceiling Panel - White Textured	76	Negative
Exterior Door Caulk - Black	77	Negative
Exterior Window Caulk - Black	78	Negative
Exterior Wall Joint Caulk - Black	79	Negative
Exterior Brick	80	Negative
Exterior Brick Mortar	81	Negative
Exterior Vent Caulk - Brown	82	Negative
Exterior Insulation Wall Panel	83	Negative
Exterior Insulation Wall Panel Caulk - White	84	Positive
Exterior Door Caulk - White	85	Negative
Exterior Beam Caulk - Gray	86	Positive
Exterior Window Glaze - Brown	87	Negative

Oxford High School
Homogeneous Area List

Homogeneous Area Description	HA#	Asbestos
Concrete	1	Negative
Cinderblock	2	Negative
Cinderblock Mortar	3	Negative
Drywall	4	Negative
Drywall Tape	5	Negative
Drywall Mud	6	Negative
2' x 4' Ceiling Panel - Dots/Gouges	7	Negative
Carpet Glue - Yellow	8	Negative
Firestop - Red	9	Negative
4"Covebase - Black	10	Negative
Mastic for 4"Covebase - Black	11	Negative
Door Caulk - White	12	Negative
Door Window Glaze - Black	13	Negative
Window Caulk - Gray	14	Negative
Fiberglass Pipe Insulation	15	Negative
Whiteboard/ Tack Board Glue Pod	16	Negative
12" x 12" Floor Tile - Beige Mottled	17	Negative
Mastic for 12" x 12" Floor Tile - Beige Mottled	18	Negative
12" x 12" Floor Tile - Cream w/ Beige Specks	19	Negative
Mastic for 12" x 12" Floor Tile - Cream w/ Beige Specks	20	Negative
Lab Table Top	21	Negative
Tagged Fire Door	22	Assumed
Tagged Fire Door Frame	23	Assumed
Duct Sealant - Gray	24	Negative
Door Caulk - New Gray	25	Negative
Brick	26	Negative
Brick Mortar	27	Negative
Wall Joint Caulk - Brown	28	Negative
Duct Sealant - Green	29	Negative
Wall Joint Caulk - Black	30	Negative
Duct Seam Putty - Grey	31	Negative
12" x 12" Floor Tile White w/ Gray Specs	32	Negative
12" x 12" Floor Tile white w/ Gray Specs Mastic	33	Negative
Wall Joint Calk - White	34	Negative
Vibration Dampener - Black	35	Negative
12" x 12" Floor Tile - Blue Mottled	36	Negative
Mastic for 12" x 12" Floor Tile - Blue Mottled	37	Negative
Vinyl Sheeting - Black	38	Negative
Mastic For Vinyl Sheeting - Black	39	Negative
Corner Covebase - Black	40	Negative
Mastic for Corner Covebase - Black	41	Negative
Stair Stringer Caulk - White	42	Negative
Tectum Acoustical Panels	43	Negative
Glue for Tectum Acoustical Panels	44	Negative
Wall Window Glaze - Black	45	Negative
2' x 4' Ceiling Panel - Textured	46	Negative
Sink Undercoating - Gray	47	Negative

Oxford High School
Homogeneous Area List

Homogeneous Area Description	HA#	Asbestos
2' x 4' Ceiling Panel - Smooth	48	Negative
Gym Wood Floor	49	Assumed
Wall Joint Caulk - Gray	50	Negative
EIFS Ceiling	51	Negative
Running Track - Blue	52	Assumed
Mastic for Running Track - Blue	53	Assumed
Epoxy Floor - Black/ Gray Marble	54	Negative
Vinyl Sheeting - Blue	55	Negative
Mastic for Vinyl Sheeting - Blue	56	Negative
12" x 12" Floor Tile - Yellow Mottled	57	Negative
Mastic for 12" x 12" Floor Tile - Yellow Mottled	58	Negative
12" x 12" Floor Tile - Back/ White Mottled	59	Negative
Mastic for 12" x 12" Floor Tile - Back/ White Mottled	60	Negative
Stair Tread - Black	61	Negative
Mastic for Stair Tread - Black	62	Negative
Gym Wood Floor (East)	63	Assumed
4"Covebase - Red	64	Negative
Mastic for 4"Covebase - Red	65	Negative
Cellulose Ceiling	66	Negative
Wall Window Caulk - Gray	67	Negative
12" x 12" Floor Tile - Red Mottled	68	Negative
Mastic for 12" x 12" Floor Tile - Red Mottled	69	Negative
Door Caulk - White (1998)	70	Negative
Duct Sealant - Tan	71	Negative
Fiberglass Duct Insulation - Paper Wrap	72	Negative
Wall Joint Caulk - White (1998)	73	Negative
Door Window Glaze Black Putty	74	Negative
Kiln Brick	75	Negative
Sink Undercoating - Black	76	Negative
Wall Window Glaze Black Putty	77	Negative
4" Covebase - Blue	78	Negative
Mastic for 4" Covebase - Blue	79	Negative
Window Caulk - Brown	80	Negative
2' x 4' Ceiling Panel - Dots/ Large Gouges	81	Negative
Partition Wall	82	Negative
Door Caulk - Brown	83	Negative
2' x 2' Ceiling Panel - Textured	84	Negative
4"Covebase - Brown	85	Negative
Mastic for 4"Covebase - Brown	86	Negative
Boiler - 2003	87	Assumed
Exterior Wall Joint Caulk - Rust	88	Negative
Exterior Wall Joint Caulk - Gray	89	Negative
Exterior Door Caulk - Brown	90	Negative
Exterior Window Caulk - Brown	91	Negative
Exterior Brick - 1998	92	Negative
Exterior Brick Mortar - 1998	93	Negative
Exterior Door Caulk - Gray	94	Negative

Oxford High School
Homogeneous Area List

Homogeneous Area Description	HA#	Asbestos
Exterior EIFS - 2004	95	Negative
Exterior Window Caulk - Gray	96	Negative
Exterior Brick - 2004	97	Negative
Exterior Brick Mortar - 2004	98	Negative
Exterior EIFS - 1998	99	Negative
Exterior EIFS Caulk - Tan - 1998	100	Negative
Exterior EIFS Caulk - Tan 2004	101	Negative