



LABORATORIES, INC.
COMPLETE WATER TESTING SERVICES
CERTIFIED WELL & SEPTIC INSPECTORS

TO: Leonard Elementary
RE: 335 E. Elmwood
WSSN: 20574-63
PURPOSE: Routine

DATE: February 22, 2021
SAMPLE NO: 47885
COLLECTED BY: AquaTest - GT

ANALYTICAL REPORT

PARAMETER	Result	Date/Time Sampled	Sample Location	Date/Time Analyzed	Analyst	EPA's MCL / AL	Reporting Limit	Testing Method
1. Total Coliform Bacteria	Not Detected	2/18/21	Kit Sink	2/18/21	3:52p	VC	0	1 cfu/100ml
2. E-Coli Bacteria	Not Detected	2/18/21	Kit Sink	2/18/21	3:52p	VC	0	1 cfu/100ml
3. Arsenic	Not Detected	2/18/21	Treated Tap	2/19/21	9:12a	VC	10 ppb	2 ppb
								SM 3113B

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.



LABORATORIES, INC.
COMPLETE WATER TESTING SERVICES
CERTIFIED WELL & SEPTIC INSPECTORS

TO: Clear Lake Elem
RE: 2085 W Drahrner
WSSN: 21413-63
PURPOSE: Routine

DATE: February 22, 2021
SAMPLE NO: 47880
COLLECTED BY: AquaTest - GT

ANALYTICAL REPORT

PARAMETER	Result	Date/Time Sampled	Sample Location	Date/Time Analyzed	Analyst	EPA's MCL / AL	Reporting Limit	Testing Method		
1. Total Coliform Bacteria	Not Detected	2/18/21	1:24p	Kit Sink	2/18/21	3:52p	VC	0	1 cfu/100ml	9223B
2. E-Coli Bacteria	Not Detected	2/18/21	1:24p	Kit Sink	2/18/21	3:52p	VC	0	1 cfu/100ml	9223B

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.