

TO: Leonard Elementary

RE: 335 E. Elmwood

WSSN: 20574-63 PURPOSE: Routine DATE: December 7, 2021

SAMPLE NO: 56013

COLLECTED BY: AT - Geoff Todd

ANALYTICAL REPORT

		Date/		Sample	Date/			EPA's	Reporting	Testing
PARAMETER	Result	Sampled		Location	Analyzed		Analyst	MCL / AL	Limit	Method
Total Coliform Bacteria	Not Detected	11/16/21	11:59a	Kit Sink	11/16/21	2:13p	TK	0	1 cfu/100ml	9223B
E-Coli Bacteria	Not Detected	11/16/21	11:59a	Kit Sink	11/16/21	2:13p	TK	0	1 cfu/100ml	9223B
3. Arsenic	2.9 ppb	11/16/21	11:49a	Treated Tap-POE	11/17/21	11:15a	VC	10 ppb	2 ppb	SM 3113B



MICHIGAN DEPARTMENT OF **ENVIRONMENT, GREAT LAKES, AND ENERGY DRINKING WATER LABORATORY**

USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270 Lansing, MI 48909

TEL: (517) 335-8184 FAX: (517) 335-8562

Official Laboratory Report

AQUATEST LABORATORIES INC Report To:

> 9165 HIGHLAND RD WHITE LAKE MI 48386

Sample ID: LJ89092

Work Order: 11101723_06

System Name/Owner:

LEONARD ELEMENTARY OXFORD SCHO

2057463

Collection Address:

335 EAST ELMWOOD, LEONARD

TYPE II

Collected By:

GEOFF TODD

Site Code:

WSSN/Pool ID:

Other

11/17/2021

Township/Well#/Section:

/001/ Oakland Collector: Date Collected:

11/16/2021

11:49 11:29

County: Sample Point: Water System:

POE TREATED TAP Public System Well

Date Received: Purpose:

Source:

Routine Monitoring

	REGULATORY INFORMATION						
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS#
Per-And Polyfluorinated Alkyl Sub	stances						
11CI-PF3OUdS	Not Detected	ng/L	2	11/18/2021		EPA 537.1	763051-92-9c
9CI-PF3ONS	Not Detected	ng/L	2	11/18/2021		EPA 537.1	756426-58-1d
ADONA	Not Detected	ng/L	2	11/18/2021		EPA 537.1	919005-14-4e
HFPO-DA	Not Detected	ng/L	2	11/18/2021	370	EPA 537.1	13252-13-6b
NEtFOSAA	Not Detected	ng/L	2	11/18/2021		EPA 537.1	2991-50-6
NMeFOSAA	Not Detected	ng/L	2	11/18/2021		EPA 537.1	2355-31-9
PFBS	Not Detected	ng/L	2	11/18/2021	420	EPA 537.1	375-73-5
PFDA	Not Detected	ng/L	2	11/18/2021		EPA 537.1	335-76-2
PFDoA	Not Detected	ng/L	2	11/18/2021		EPA 537.1	307-55-1
PFHpA	Not Detected	ng/L	2	11/18/2021		EPA 537.1	375-85-9
PFHxA	Not Detected	ng/L	2	11/18/2021	400000	EPA 537.1	307-24-4
PFHxS	Not Detected	ng/L	2	11/18/2021	51	EPA 537.1	355-46-4
PFNA	Not Detected	ng/L	2	11/18/2021	6	EPA 537.1	375-95-1
PFOA	Not Detected	ng/L	2	11/18/2021	8	EPA 537.1	335-67-1
PFOS	Not Detected	ng/L	2	11/18/2021	16	EPA 537.1	1763-23-1
PFTA	Not Detected	ng/L	2	11/18/2021		EPA 537.1	376-06-7
PFTrDA	Not Detected	ng/L	2	11/18/2021		EPA 537.1	72629-94-8
PFUnA	Not Detected	ng/L	2	11/18/2021		EPA 537,1	2058-94-8

RL: Reporting Limit

MCL: Maximum Contaminant Level

Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm) ng/L: nanograms / Liter (ppt) MPN: Most Probable Number

CFU: Colony Forming Unit CAS: Chemical Abstract Service Laboratory Contact: Marlene Kane