



TO: Clear Lake Elem
RE: 2085 W Drahner
WSSN: 21413-63
PURPOSE: Routine

DATE: December 8, 2021
SAMPLE NO: 56012
COLLECTED BY: AquaTest - GT

ANALYTICAL REPORT

PARAMETER	Result	Date/Time Sampled		Sample Location	Date/Time Analyzed		Analyst	EPA's MCL / AL	Reporting Limit	Testing Method
1. Total Coliform Bacteria	Not Detected	11/16/21	9:38a	Kit 3 Comp Sink	11/16/21	2:13p	TK	0	1 cfu/100ml	9223B
2. E-Coli Bacteria	Not Detected	11/16/21	9:38a	Kit 3 Comp Sink	11/16/21	2:13p	TK	0	1 cfu/100ml	9223B

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.

EPA LABORATORY #MI 01189 MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY LABORATORY #9975

21-56012 Nov Bact Clear Lk Elem

9165 HIGHLAND ROAD, WHITE LAKE, MI 248-698-9500 info@aquatestlabs.com