



TO: Clear Lake Elem
 RE: 2085 W Drahrner
 WSSN: 21413-63

DATE: February 14, 2018
 SAMPLE NO: 27019
 COLLECTED BY: GT

ANALYTICAL REPORT

PARAMETER	Result	Date/Time Sampled	Sample Location	Date/Time Analyzed	Analyst	EPA's MCL / AL	Reporting Limit	Testing Method
1. Total Coliform Bacteria	Not Detected	2/12/18 10:09a	Drinking Fnth	2/12/18 1:36p	VC	0	1 cfu/100ml	9223B
2. E-Coli Bacteria	Not Detected	2/12/18 10:09a	Drinking Fnth	2/12/18 1:36p	VC	0	1 cfu/100ml	9223B
1. Nitrates	Not Detected	2/12/18 10:40a	Sample Tap	2/12/18 2:32p	VC	10 ppm	1 ppm	Hach10206
2. Nitrites	Not Detected	2/12/18 10:40a	Sample Tap	2/12/18 2:32p	VC	1 ppm	0.10 ppm	4500-NO2-B

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety. This report is for the use of the above addressed person and is for informational purposes only.