



TO: Leonard Elementary
RE: 335 E. Elmwood
WSSN: 20574-63
PURPOSE: Routine

DATE: April 16, 2021
SAMPLE NO: 49076
COLLECTED BY: AquaTest - GT

ANALYTICAL REPORT

PARAMETER	Result	Date/Time Sampled		Sample Location	Date/Time Analyzed		Analyst	EPA's MCL / AL	Reporting Limit	Testing Method
1. Total Coliform Bacteria	Not Detected	4/14/21	9:11a	Kit Sink	4/14/21	2:39p	PG	0	1 cfu/100ml	9223B
2. E-Coli Bacteria	Not Detected	4/14/21	9:11a	Kit Sink	4/14/21	2:39p	PG	0	1 cfu/100ml	9223B
3. Nitrates	Not Detected	4/14/21	9:21a	Sample Tap	4/14/21	2:58p	PG	10 ppm	1 ppm	Hach10206
4. Nitrites	Not Detected	4/14/21	9:21a	Sample Tap	4/14/21	2:58p	PG	1 ppm	0.10 ppm	4500-NO ₂ -B
5. Arsenic	Not Detected	4/14/21	9:17a	Treated Tap	4/15/21	9:01a	VC	10 ppb	2 ppb	SM 3113B

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.