



LABORATORIES, INC.
COMPLETE WATER TESTING SERVICES
CERTIFIED WELL & SEPTIC INSPECTORS

TO: Leonard Elementary
RE: 335 E. Elmwood
WSSN: 20574-63

DATE: January 25, 2018
SAMPLE NO: 26633
COLLECTED BY: Aquatest GT

ANALYTICAL REPORT

PARAMETER	Result	Date/Time Sampled		Sample Location	Date/Time Analyzed		Analyst	EPA's MCL / AL	Reporting Limit	Testing Method
1. Total Coliform Bacteria	Not Detected	1/23/18	8:54a	Kitchen Sink	1/23/18	2:09p	LP	0	1 cfu/100ml	9223B
2. E-Coli Bacteria	Not Detected	1/23/18	8:54a	Kitchen Sink	1/23/18	2:09p	LP	0	1 cfu/100ml	9223B
3. Nitrates	Not Detected	1/23/18	9:04a	Sample Tap	1/23/18	3:08p	LP	10 ppm	1 ppm	Hach10206
4. Nitrites	Not Detected	1/23/18	9:04a	Sample Tap	1/23/18	3:08p	LP	1 ppm	0.10 ppm	4500-NO2-B
5. Arsenic	4.7 ppb	1/23/18	9:00a	Treated Tap	1/24/18	8:36a	VC	10 ppb	2 ppb	SM 3113B

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.