

AquaTest



LABORATORIES, INC.

COMPLETE WATER TESTING SERVICES
CERTIFIED WELL & SEPTIC INSPECTORS

TO: Leonard Elementary
RE: 335 E. Elmwood
WSSN: 20574-63

DATE: November 30, 2017
SAMPLE NO: 25823
COLLECTED BY: Aquatest GT

ANALYTICAL REPORT

PARAMETER	Result	Date/Time Sampled		Sample Location	Date/Time Analyzed		Analyst	EPA's MCL / AL	Reporting Limit	Testing Method
1. Total Coliform Bacteria	Not Detected	11/13/17	10:24a	Kitchen Sink	11/13/17	2:37p	VC	0	1 cfu/100ml	9223B
2. E-Coli Bacteria	Not Detected	11/13/17	10:24a	Kitchen Sink	11/13/17	2:37p	VC	0	1 cfu/100ml	9223B

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.