

# AquaTest



LABORATORIES, INC.

COMPLETE WATER TESTING SERVICES  
CERTIFIED WELL & SEPTIC INSPECTORS

TO: Leonard Elementary  
RE: 335 E. Elmwood  
WSSN: 20574-63

DATE: November 3, 2017  
SAMPLE NO: 25398  
COLLECTED BY: Aquatest GT

## ANALYTICAL REPORT

PARAMETER	Result	Date/Time Sampled		Sample Location	Date/Time Analyzed		Analyst	EPA's MCL / AL	Reporting Limit	Testing Method
1. Total Coliform Bacteria	Not Detected	10/25/17	9:35a	Kitchen Sink	10/25/17	1:47p	VC	0	1 cfu/100ml	9223B
2. E-Coli Bacteria	Not Detected	10/25/17	9:35a	Kitchen Sink	10/25/17	1:47p	VC	0	1 cfu/100ml	9223B
1. Total Coliform Bacteria	Not Detected	10/25/17	9:35a	Fntn - Hall by Gym	10/25/17	1:47p	VC	0	1 cfu/100ml	9223B
2. E-Coli Bacteria	Not Detected	10/25/17	9:35a	Fntn - Hall by Gym	10/25/17	1:47p	VC	0	1 cfu/100ml	9223B
1. Total Coliform Bacteria	Not Detected	10/25/17	9:35a	Fntn - Hall by Rm 25	10/25/17	1:47p	VC	0	1 cfu/100ml	9223B
2. E-Coli Bacteria	Not Detected	10/25/17	9:35a	Fntn - Hall by Rm 25	10/25/17	1:47p	VC	0	1 cfu/100ml	9223B
3. Arsenic	5.5 ppb	10/25/17	9:35a	Treated Tap	10/26/17	8:47a	VC	10 ppb	2 ppb	SM 3113B

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.

EPA LABORATORY #MI 01189 MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY LABORATORY #9975

17-25398 Oct Ars Bact Leonard El

9165 HIGHLAND ROAD, WHITE LAKE, MI 248-698-9500 info@aquatestlabs.com