



LABORATORIES, INC.
 COMPLETE WATER TESTING SERVICES
 CERTIFIED WELL & SEPTIC INSPECTORS

TO: Oxford Middle School
RE: 1420 Lakeville Rd.; Oxford
WSSN: NA
COUNTY: Oakland

DATE: July 7, 2016
SAMPLE NO: 16093
COLLECTED BY: GT
RECEIVED: Acceptable

ANALYTICAL REPORT

PARAMETER	Result (ppb)	Date/Time Sampled		Site Code / Sample Location		Date/Time Analyzed		Analyst	EPA's MCL / AL	Reporting Limit	Testing Method
Analyzed at Laboratory #9925											
1. Copper	270	6/14/16	8:21 AM	Drinking Fntrn	Gym	6/19/16	5:59 PM	TA	1300 ppb	5 ppb	EPA 200.8
1. Lead	2	6/14/16	8:21 AM	Drinking Fntrn	Gym	6/19/16	5:59 PM	TA	15 ppb	1.0 ppb	EPA 200.8
2. Copper	46	6/14/16	8:24 AM	Sink	Kitchen Prep L	6/19/16	5:31 PM	TA	1300 ppb	5 ppb	EPA 200.8
2. Lead	2.7	6/14/16	8:24 AM	Sink	Kitchen Prep L	6/19/16	5:31 PM	TA	15 ppb	1.0 ppb	EPA 200.8
3. Copper	56	6/14/16	8:25 AM	Sink	Kitchen Prep R	6/19/16	5:12 PM	TA	1300 ppb	5 ppb	EPA 200.8
3. Lead	2.2	6/14/16	8:25 AM	Sink	Kitchen Prep R	6/19/16	5:12 PM	TA	15 ppb	1.0 ppb	EPA 200.8
4. Copper	230	6/14/16	8:28 AM	Fountain	Hall	6/19/16	9:18 PM	TA	1300 ppb	5 ppb	EPA 200.8
4. Lead	Not Detected	6/14/16	8:28 AM	Fountain	Boys Locker Room	6/19/16	9:18 PM	TA	15 ppb	1.0 ppb	EPA 200.8
5. Copper	400	6/14/16	8:30 AM	Fountain	6th Grade	6/20/16	12:38 AM	TA	1300 ppb	5 ppb	EPA 200.8
5. Lead	Not Detected	6/14/16	8:30 AM	Fountain	Boys Locker Room	6/20/16	12:38 AM	TA	15 ppb	1.0 ppb	EPA 200.8
6. Copper	510	6/14/16	8:33 AM	Fountain	Main	6/20/16	12:43 AM	TA	1300 ppb	5 ppb	EPA 200.8
6. Lead	Not Detected	6/14/16	8:33 AM	Fountain	Boys Locker Room	6/20/16	12:43 AM	TA	15 ppb	1.0 ppb	EPA 200.8
7. Copper	350	6/14/16	8:37 AM	Fountain	Main	6/19/16	10:32 PM	TA	1300 ppb	5 ppb	EPA 200.8
7. Lead	Not Detected	6/14/16	8:37 AM	Fountain	Girls Locker Room	6/19/16	10:32 PM	TA	15 ppb	1.0 ppb	EPA 200.8
8. Copper	830	6/14/16	8:39 AM	Fountain	6th Grade Girls	6/19/16	8:27 PM	TA	1300 ppb	5 ppb	EPA 200.8
8. Lead	15	6/14/16	8:39 AM	Fountain	6th Grad Girls	6/19/16	8:27 PM	TA	15 ppb	1.0 ppb	EPA 200.8
9. Copper	160	6/14/16	8:40 AM	Fountain	Hall	6/19/16	5:08 PM	TA	1300 ppb	5 ppb	EPA 200.8
9. Lead	Not Detected	6/14/16	8:40 AM	Fountain	Girls Locker Room	6/19/16	5:08 PM	TA	15 ppb	1.0 ppb	EPA 200.8
10. Copper	390	6/14/16	8:45 AM	Fountain	Main Entrance	6/19/16	11:24 PM	TA	1300 ppb	5 ppb	EPA 200.8
10. Lead	3.7	6/14/16	8:45 AM	Fountain	Main Entrance	6/19/16	11:24 PM	TA	15 ppb	1.0 ppb	EPA 200.8

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.



LABORATORIES, INC.

COMPLETE WATER TESTING SERVICES
CERTIFIED WELL & SEPTIC INSPECTORS

TO: Oxford Middle School
RE: 1420 Lakeville Rd.; Oxford
WSSN: NA
COUNTY: Oakland

DATE: July 7, 2016
SAMPLE NO: =N12
COLLECTED BY: GT
RECEIVED: Acceptable

ANALYTICAL REPORT

PARAMETER	Result (ppb)	Date/Time Sampled		Site Code / Sample Location		Date/Time Analyzed		Analyst	EPA's MCL / AL	Reporting Limit	Testing Method
Analyzed at Laboratory #9925											
11. Copper	500	6/14/16	8:48 AM	Fountain	116 Left	6/19/16	9:13 PM	TA	1300 ppb	5 ppb	EPA 200.8
11. Lead	1.7	6/14/16	8:48 AM	Fountain	116 Left	6/19/16	9:13 PM	TA	15 ppb	1.0 ppb	EPA 200.8
12. Copper	230	6/14/16	8:49 AM	Fountain	116 Right	6/19/16	8:55 PM	TA	1300 ppb	5 ppb	EPA 200.8
12. Lead	Not Detected	6/14/16	8:49 AM	Fountain	116 Right	6/19/16	8:55 PM	TA	15 ppb	1.0 ppb	EPA 200.8
13. Copper	390	6/14/16	8:51 AM	Fountain	139 Left	6/19/16	8:41 PM	TA	1300 ppb	5 ppb	EPA 200.8
13. Lead	Not Detected	6/14/16	8:51 AM	Fountain	139 Left	6/19/16	8:41 PM	TA	15 ppb	1.0 ppb	EPA 200.8
14. Copper	260	6/14/16	8:52 AM	Fountain	225 Right	6/19/16	8:59 PM	TA	1300 ppb	5 ppb	EPA 200.8
14. Lead	1.3	6/14/16	8:52 AM	Fountain	225 Right	6/19/16	8:59 PM	TA	15 ppb	1.0 ppb	EPA 200.8
15. Copper	420	6/14/16	8:53 AM	Fountain	225 F	6/19/16	5:26 PM	TA	1300 ppb	5 ppb	EPA 200.8
15. Lead	1.6	6/14/16	8:53 AM	Fountain	225 F	6/19/16	5:26 PM	TA	15 ppb	1.0 ppb	EPA 200.8
16. Copper	390	6/14/16	9:00 AM	Fountain	216 Left	6/19/16	5:45 PM	TA	1300 ppb	5 ppb	EPA 200.8
16. Lead	Not Detected	6/14/16	9:00 AM	Fountain	216 Left	6/19/16	5:45 PM	TA	15 ppb	1.0 ppb	EPA 200.8
17. Copper	480	6/14/16	9:04 AM	Fountain	202	6/19/16	10:56 PM	TA	1300 ppb	5 ppb	EPA 200.8
17. Lead	Not Detected	6/14/16	9:04 AM	Fountain	202	6/19/16	10:56 PM	TA	15 ppb	1.0 ppb	EPA 200.8

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.

EPA LABORATORY #MI 01189 MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY LABORATORY #9975
9165 HIGHLAND ROAD, WHITE LAKE, MI 248-698-9500 info@aquatestlabs.com



LABORATORIES, INC.

COMPLETE WATER TESTING SERVICES
CERTIFIED WELL & SEPTIC INSPECTORS

UNDERSTANDING YOUR REPORT

Terms	Explanation
-------	-------------

Parameter	The contaminate we tested for in your sample.
Result	The actual findings of your test.
Not Detected	The contaminate was not found above the reporting limit.
Positive	In an absence/presence test the contaminate was found.
cfu	Colony forming unit is an estimate of viable bacterial or fungal numbers.
ppm	Parts per million denotes one part per 1,000,000 parts; This is equivalent to one drop of water diluted into 50 liters
ppb	Parts per billion denotes one part per 1,000,000,000 parts; This is equivalent to one drop of water diluted into 250 chemical drums.
pCi/L	Picocuries per Liter is a measure of the radioactivity in water.
Date/Time Sam	The date and time the water was collected.
Sample Locatio	This tells you where the sample was collected.
Date/Time Analy	The date and time the water was tested.
Holding Time	The time between sample collection and testing; for compliance must not exceed 30 hours for Total Coliform, 48 hours for Nitrates/Nitrites.
Analyst	The initials of the location or of who tested your water.
EPA	Environmental Protection Agency is a government agency whose purpose is to protect human health and the environment.
MCL	Maximum Contaminate Level is highest amount of a contaminate allowed for safe drinking water set by the EPA.
AL	Action Level - EPA level If exceeded triggers treatment or other requirements.
NSDWS	National Secondary Drinking Water Standard is an unenforceable recommended limit of a contaminate set by the EPA.
Reporting Limit	The reporting limit is a quality control measure. A parameter would need to be above this level to register a reliable result.
Testing Method	The testing method is the procedure we used to test your sample.

More information on drinking water and the Environmental Protection Agency can be found at: <http://water.epa.gov/drink/>

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.

EPA LABORATORY #MI 01189 MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY LABORATORY #9975
9165 HIGHLAND ROAD, WHITE LAKE, MI 248-698-9500 info@aquatestlabs.com