



LABORATORIES, INC.

COMPLETE WATER TESTING SERVICES
CERTIFIED WELL & SEPTIC INSPECTORS

TO: Oxford Elementary
RE: 109 Pontiac St
WSSN: NA
COUNTY: Oakland

DATE: August 31, 2016
SAMPLE NO: 17612
COLLECTED BY: GT
RECEIVED: Acceptable

ANALYTICAL REPORT

PARAMETER	Result (ppb)	Date/Time Sampled		Site Code / Sample Location		Date/Time Analyzed		Analyst	EPA's MCL / AL	Reporting Limit	Testing Method	
Analyzed at Laboratory #9925												
1. Copper	470	8/9/16	7:25 AM	Fountain	Cafeteria	8/16/16	9:16 AM	TA	1300 ppb	5 ppb	EPA 200.8	
1. Lead	Not Detected	8/9/16	7:25 AM	Fountain	Cafeteria	8/16/16	9:16 AM	TA	15 ppb	1.0 ppb	EPA 200.8	
2. Copper	710	8/9/16	7:27 AM	Prep Sink	Kitchen	8/16/16	9:32 AM	TA	1300 ppb	5 ppb	EPA 200.8	
2. Lead	1	8/9/16	7:27 AM	Prep Sink	Kitchen	8/16/16	9:32 AM	TA	15 ppb	1.0 ppb	EPA 200.8	
4. Copper	780	8/9/16	7:30 AM	Fountain	Rm 405	8/16/16	9:27 AM	TA	1300 ppb	5 ppb	EPA 200.8	
4. Lead	Not Detected	8/9/16	7:30 AM	Fountain	Rm 405	8/16/16	9:27 AM	TA	15 ppb	1.0 ppb	EPA 200.8	
6. Copper	400	8/9/16	7:38 AM	Fountain	Rm 406	8/12/16	7:02 PM	TA	1300 ppb	5 ppb	EPA 200.8	
6. Lead	Not Detected	8/9/16	7:38 AM	Fountain	Rm 406	8/12/16	7:02 PM	TA	15 ppb	1.0 ppb	EPA 200.8	
8. Copper	540	8/9/16	7:41 AM	Fountain	Rm 407	8/16/16	9:02 AM	TA	1300 ppb	5 ppb	EPA 200.8	
8. Lead	Not Detected	8/9/16	7:41 AM	Fountain	Rm 407	8/16/16	9:02 AM	TA	15 ppb	1.0 ppb	EPA 200.8	
10. Copper	670	8/9/16	7:44 AM	Fountain	Rm 408	8/16/16	8:46 AM	TA	1300 ppb	5 ppb	EPA 200.8	
10. Lead	Not Detected	8/9/16	7:44 AM	Fountain	Rm 408	8/16/16	8:46 AM	TA	15 ppb	1.0 ppb	EPA 200.8	
12. Copper	690	8/9/16	7:48 AM	Fountain	Rm 409	8/16/16	8:38 AM	TA	1300 ppb	5 ppb	EPA 200.8	
12. Lead	Not Detected	8/9/16	7:48 AM	Fountain	Rm 409	8/16/16	8:38 AM	TA	15 ppb	1.0 ppb	EPA 200.8	
13. Copper	340	8/9/16	7:53 AM	Fountain	3rd Grade	8/12/16	6:52 PM	TA	1300 ppb	5 ppb	EPA 200.8	
13. Lead	Not Detected	8/9/16	7:53 AM	Fountain	Commons	8/12/16	6:52 PM	TA	15 ppb	1.0 ppb	EPA 200.8	
14. Copper	640	8/9/16	7:56 AM	Sink	Staff Lounge	8/16/16	8:57 AM	TA	1300 ppb	5 ppb	EPA 200.8	
14. Lead	Not Detected	8/9/16	7:56 AM	Sink	Staff Lounge	8/16/16	8:57 AM	TA	15 ppb	1.0 ppb	EPA 200.8	
15. Copper	800	8/9/16	7:58 AM	Fountain	Lower Near Office	8/12/16	7:12 PM	TA	1300 ppb	5 ppb	EPA 200.8	
15. Lead	Not Detected	8/9/16	7:58 AM	Fountain	Lower Near Office	8/12/16	7:12 PM	TA	15 ppb	1.0 ppb	EPA 200.8	

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.

EPA LABORATORY #MI 01189 MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY LABORATORY #9975
9165 HIGHLAND ROAD, WHITE LAKE, MI 248-698-9500 info@aquatestlabs.com



LABORATORIES, INC.

COMPLETE WATER TESTING SERVICES
CERTIFIED WELL & SEPTIC INSPECTORS

IO: Oxford Elementary
RE: 109 Pontiac St
WSSN: NA
COUNTY: Oakland

DATE: August 31, 2016
SAMPLE NO: 17612
COLLECTED BY: GT
RECEIVED: Acceptable

ANALYTICAL REPORT

PARAMETER	Result (ppb)	Date/Time Sampled		Site Code / Sample Location		Date/Time Analyzed		Analyst	EPA's MCL / AL	Reporting Limit	Testing Method
Analyzed at Laboratory #9925											
16. Copper	770	8/9/16	8:01 AM	Fountain	Upper Near Office	8/16/16	9:35 AM	TA	1300 ppb	5 ppb	EPA 200.8
16. Lead	Not Detected	8/9/16	8:01 AM	Fountain	Upper Near Office	8/16/16	9:35 AM	TA	15 ppb	1.0 ppb	EPA 200.8
18. Copper	130	8/9/16	8:08 AM	Fountain	7307	8/12/16	6:39 PM	TA	1300 ppb	5 ppb	EPA 200.8
18. Lead	1.4	8/9/16	8:08 AM	Fountain	7307	8/12/16	6:39 PM	TA	15 ppb	1.0 ppb	EPA 200.8
19. Copper	480	8/9/16	8:10 AM	Fountain	ELC	8/16/16	9:29 AM	TA	1300 ppb	5 ppb	EPA 200.8
19. Lead	Not Detected	8/9/16	8:10 AM	Fountain	ELC	8/16/16	9:29 AM	TA	15 ppb	1.0 ppb	EPA 200.8

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.

EPA LABORATORY #MI 01189 MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY LABORATORY #9975
9165 HIGHLAND ROAD, WHITE LAKE, MI 248-698-9500 info@aquatestlabs.com



LABORATORIES, INC.

COMPLETE WATER TESTING SERVICES
CERTIFIED WELL & SEPTIC INSPECTORS

UNDERSTANDING YOUR REPORT

Terms	Explanation
Parameter	The contaminate we tested for in your sample.
Result	The actual findings of your test.
Not Detected	The contaminate was not found above the reporting limit.
Positive	In an absence/presence test the contaminate was found.
cfu	Colony forming unit is an estimate of viable bacterial or fungal numbers.
ppm	Parts per million denotes one part per 1,000,000 parts; This is equivalent to one drop of water diluted into 50 liters
ppb	Parts per billion denotes one part per 1,000,000,000 parts; This is equivalent to one drop of water diluted into 250 chemical drums.
pCi/L	Picocuries per Liter is a measure of the radioactivity in water.
Date/Time Sam	The date and time the water was collected.
Sample Locatio	This tells you where the sample was collected.
Date/Time Anal	The date and time the water was tested.
Holding Time	The time between sample collection and testing; for compliance must not exceed 30 hours for Total Coliform, 48 hours for Nitrates/Nitrites.
Analyst	The initials of the location or of who tested your water.
EPA	Environmental Protection Agency is a government agency whose purpose is to protect human health and the environment.
MCL	Maximum Contaminate Level is highest amount of a contaminate allowed for safe drinking water set by the EPA.
AL	Action Level - EPA level If exceeded triggers treatment or other requirements.
NSDWS	National Secondary Drinking Water Standard is an unenforceable recommended limit of a contaminate set by the EPA.
Reporting Limit	The reporting limit is a quality control measure. A parameter would need to be above this level to register a reliable result.
Testing Method	The testing method is the procedure we used to test your sample.

More information on drinking water and the Environmental Protection Agency can be found at: <http://water.epa.gov/drink/>

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.

EPA LABORATORY #MI 01189 MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY LABORATORY #9975
9165 HIGHLAND ROAD, WHITE LAKE, MI 248-698-9500 info@aquatestlabs.com