



LABORATORIES, INC.
 COMPLETE WATER TESTING SERVICES
 CERTIFIED WELL & SEPTIC INSPECTORS

TO: Leonard Elementary
RE: 335 E. Elmwood
WSSN: 20574-63

DATE: September 26, 2017
SAMPLE NO: 24863
COLLECTED BY: Aquatest - GT

ANALYTICAL REPORT

PARAMETER	Result	Date/Time Sampled		Sample Location	Date/Time Analyzed		Analyst	EPA's MCL / AL	Reporting Limit	Testing Method
1. Total Coliform Bacteria	25.9 cfu	9/25/17	8:51 AM	Kit Sink	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
1. E-Coli Bacteria	Not Detected	9/25/17	8:51 AM	Kit Sink	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
2. Total Coliform Bacteria	12.0 cfu	9/25/17	8:20 AM	Gym Drinking Fntn	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
2. E-Coli Bacteria	Not Detected	9/25/17	8:20 AM	Gym Drinking Fntn	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
3. Total Coliform Bacteria	22.8 cfu	9/25/17	8:58 AM	Teach Lounge sink	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
3. E-Coli Bacteria	Not Detected	9/25/17	8:58 AM	Teach Lounge sink	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
4. Total Coliform Bacteria	17.5 cfu	9/25/17	8:16 AM	Art Sink	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
4. E-Coli Bacteria	Not Detected	9/25/17	8:16 AM	Art Sink	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
5. Total Coliform Bacteria	Not Detected	9/25/17	8:25 AM	Fntn 24	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
5. E-Coli Bacteria	Not Detected	9/25/17	8:25 AM	Fntn 24	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
6. Total Coliform Bacteria	Not Detected	9/25/17	8:26 AM	Fntn 25	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
6. E-Coli Bacteria	Not Detected	9/25/17	8:26 AM	Fntn 25	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
7. Total Coliform Bacteria	Not Detected	9/25/17	8:32 AM	Fntn 16a	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
7. E-Coli Bacteria	Not Detected	9/25/17	8:32 AM	Fntn 16a	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
8. Total Coliform Bacteria	Not Detected	9/25/17	8:33 AM	Fntn 16b	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
8. E-Coli Bacteria	Not Detected	9/25/17	8:33 AM	Fntn 16b	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
9. Total Coliform Bacteria	Not Detected	9/25/17	8:39 AM	Rm 12 Sink	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
9. E-Coli Bacteria	Not Detected	9/25/17	8:39 AM	Rm 12 Sink	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
10. Total Coliform Bacteria	28.8 cfu	9/25/17	8:43 AM	Sample Tap	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
10 E-Coli Bacteria	Not Detected	9/25/17	8:43 AM	Sample Tap	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B

AquaTest



LABORATORIES, INC.

COMPLETE WATER TESTING SERVICES
CERTIFIED WELL & SEPTIC INSPECTORS

TO: Leonard Elementary
RE: 335 E. Elmwood
WSSN: 20574-63

DATE: September 26, 2017
SAMPLE NO: 24863
COLLECTED BY: Aquatest - GT

ANALYTICAL REPORT

PARAMETER	Result	Date/Time Sampled		Sample Location	Date/Time Analyzed		Analyst	EPA's MCL / AL	Reporting Limit	Testing Method
11. Total Coliform Bacteria	51.2 cfu	9/25/17	8:44 AM	Sample Tap	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
11. E-Coli Bacteria	Not Detected	9/25/17	8:44 AM	Sample Tap	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
12. Total Coliform Bacteria	53.8 cfu	9/25/17	8:45 AM	Sample Tap	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B
12. E-Coli Bacteria	Not Detected	9/25/17	8:45 AM	Sample Tap	9/25/17	11:35 AM	LP	0	1 cfu/100ml	9223B



UNDERSTANDING YOUR REPORT

Terms	Explanation
Parameter	The contaminate we tested for in your sample.
Result	The actual findings of your test.
Not Detected	The contaminate was not found above the reporting limit.
Positive	In an absence/presence test the contaminate was found.
cfu	Colony forming unit is an estimate of viable bacterial or fungal numbers.
ppm	Parts per million denotes one part per 1,000,000 parts; This is equivalent to one drop of water diluted into 50 liters
ppb	Parts per billion denotes one part per 1,000,000,000 parts; This is equivalent to one drop of water diluted into 250 chemical drums.
pCi/L	Picocuries per Liter is a measure of the radioactivity in water.
Date/Time Sampled	The date and time the water was collected.
Sample Location	This tells you where the sample was collected.
Date/Time Analyzed	The date and time the water was tested.
Holding Time	The time between sample collection and testing; for compliance must not exceed 30 hours for Total Coliform, 48 hours for Nitrates/Nitrites.
Analyst	The initials of the location or of who tested your water.
EPA	Environmental Protection Agency is a government agency whose purpose is to protect human health and the environment.
MCL	Maximum Contaminate Level is highest amount of a contaminate allowed for safe drinking water set by the EPA.
AL	Action Level - EPA level If exceeded triggers treatment or other requirements.
NSDWS	National Secondary Drinking Water Standard is an unenforceable recommended limit of a contaminate set by the EPA.
Reporting Limit	The reporting limit is a quality control measure. A parameter would need to be above this level to register a reliable result.
Testing Method	The testing method is the procedure we used to test your sample.

More information on drinking water and the Environmental Protection Agency can be found at: <http://water.epa.gov/drink/>